

# ELECTRICAL INSTALLATION CONDITION REPORT

GL00000566 - Master



## A. Details of the Client/Person Ordering the Report

Client: Hawkesbury Hospital Hall  
Address: The Village Hall  
High Street  
Hawkesbury Upton  
South Gloucester  
GL9 1AU

## B. Reason for Producing this Report

Purpose of this report:  
Client instruction  
Date(s) on which Inspection:  
and testing was carried out 12/05/2022

## C. Details of the Installation which is the Subject of this Report

Installation: Village Hall  
Occupier: Occupier  
Address: The Village Hall  
High Street  
Hawkesbury Upton  
South Gloucester GL9 1AU

Description of premises: Domestic  Commercial  Industrial   
Other: N/A  
Estimated age of wiring system: 35 yrs  
Evidence of alterations or additions:  If yes estimated Age 5 yrs  
Date of previous inspection: 15/02/2017

Record of Installation available:  N/A Records held By:  N/A

## D. Extent and Limitations Inspection and Testing

Extent of Electrical Installation covered by this report:  
All existing switchgear including DB1, DB2, DB3 & DB4

Agreed limitations including the reasons (See regulation 653.2)  
No access to high level lights - readings taken at switch in main  
--See Additional Page--

Operational Limitations including the reasons (See page No  N/A )  
None

Client

This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2018 (IET Wiring Regulations) as amended to February 2022  
It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

## E. Summary of the Condition of the Installation

General condition of the installations (In terms of electrical safety)

Evidence of upgrade works within the past couple of years - Mostly satisfactory

Overall assessment of the installation  Satisfactory \*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

## F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as SATISFACTORY, I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by 02/08/2027

## G. Declaration

I, , being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Trading Title and address: Glenroy Limited,  
20 Siston Park,  
Kingswood,  
Bristol,  
South Gloucestershire, BS15 4PE

PartP Registration Number 0282850

### Inspected and tested by:

Name M A Jones Position Test Engineer Signature Date 03/08/2022

### Report authorised for issue by:

Name P Thompson Position Qualifying Supervisor Signature Date 03/08/2022

## H. Schedule(s)

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

4 Schedule(s) of inspection and 4 Schedule(s) of test results are attached

**I. Supply Characteristics and Earthing Arrangements**

Earthing Arrangements	Number and Type of Live Conductors				Nature of Supply Parameters			Supply protective device		
TN-S <input type="checkbox"/> N/A	a.c.	<input checked="" type="checkbox"/>		d.c.	<input type="checkbox"/> N/A	Nominal Voltage $U^{(1)}$	<input type="text" value="400"/> V	BS(EN)		
TN-C-S <input checked="" type="checkbox"/>	1-Phase (2 wire)	<input type="checkbox"/> N/A	1-Phase (3 wire)	<input type="checkbox"/> N/A	2 Wire	<input type="checkbox"/> N/A	Nominal Voltage $U_0^{(1)}$	<input type="text" value="230"/> V	<input type="text" value="1361 Fuse HBC"/>	
TN-C <input type="checkbox"/> N/A	2-Phase (3 wire)	<input type="checkbox"/> N/A			3 Wire	<input type="checkbox"/> N/A	Nominal frequency $f^{(1)}$	<input type="text" value="50"/> Hz	Type	
TT <input type="checkbox"/> N/A	3-Phase (3 wire)	<input type="checkbox"/> N/A	3-Phase (4 wire)	<input checked="" type="checkbox"/>	Other	<input type="checkbox"/> N/A	Prospective fault current $I_{pf}^{(2)}$	<input type="text" value="2.232"/> kA	<input type="text" value="2"/>	
IT <input type="checkbox"/> N/A	Other	<input type="text" value="N/A"/>					External loop impedance $Z_e^{(2)}$	<input type="text" value="0.19"/> $\Omega$	Nominal current rating	
	Confirmation of supply polarity				<input checked="" type="checkbox"/>		Number of supplies	<input type="text" value="1"/>	<input type="text" value="100"/> A	
						(Note: (1) by enquiry, (2) by enquiry or by measurement)			Short circuit capacity	<input type="text" value="33"/> kA

**J. Particulars of Installation Referred to in the Report**

Means of earthing	Details of installation Earth Electrode (where applicable)		
Distributor's facility <input checked="" type="checkbox"/>	Type (e.g. rod(s), tape etc.)	<input type="text" value="N/A"/>	Location
Installation earth electrode <input type="checkbox"/> N/A	Resistance to Earth	<input type="text" value="N/A"/> $\Omega$	<input type="text" value="N/A"/>
			Method of measurement
			<input type="text" value="N/A"/>

**Main Protective Conductors** Tick boxes and enter details as applicable

Earthing Conductor	Material	<input type="text" value="Copper"/>	csa	<input type="text" value="25"/>	mm <sup>2</sup>	Continuity Verified	<input checked="" type="checkbox"/>	Connection Verified	<input checked="" type="checkbox"/>
Main protective bonding conductors	Material	<input type="text" value="Copper"/>	csa	<input type="text" value="10"/>	mm <sup>2</sup>	Continuity Verified	<input checked="" type="checkbox"/>	Connection Verified	<input checked="" type="checkbox"/>

Bonding of Incoming Service					Maximum Demand (Load)			
Water installation pipes	<input checked="" type="checkbox"/>	Gas installation pipes	<input type="checkbox"/> N/A	Structural Steel	<input type="checkbox"/> N/A	Lightning protection	<input type="checkbox"/> N/A	<input type="text" value="59"/> Amps
Oil installation pipes	<input checked="" type="checkbox"/>	Please State			Protective measure(s) against electric shock			<input type="text" value="ADS"/>
Other incoming service(s)	<input type="checkbox"/> N/A	<input type="checkbox"/> N/A						

**Main Switch / Switch-Fuse / Circuit-Breaker / RCD**

Location	<input type="text" value="Hall area - rear"/>			Current rating	<input type="text" value="100"/> A	<b>if RCD main switch</b>	
Type BS(EN)	<input type="text" value="60947-3"/>	No of poles	<input type="text" value="4"/>	Fuse/Device rating or setting	<input type="text" value="125"/> A	Rated residual operation current, $I_{\Delta n}$	<input type="text" value="N/A"/> mA
Supply Conductors material	<input type="text" value="Copper"/>	Supply Conductors csa	<input type="text" value="25"/> mm <sup>2</sup>	Voltage rating	<input type="text" value="230"/> V	Rated time delay	<input type="text" value="N/A"/> ms
						RCD Operating time at, $I_{\Delta n}$	<input type="text" value="N/A"/> ms

**K. Observations**

Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.

No remedial action is required.  The following observations are made

Item No	Observations	Code

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 - Danger present. Risk of injury. Immediate remedial action required	<input type="text" value="0"/>
C2 - Potentially dangerous - urgent remedial action required	<input type="text" value="0"/>
C3 - Improvement recommended	<input type="text" value="0"/>
FI - Further investigation required without delay	<input type="text" value="0"/>

**CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY**

Note: this form is suitable for many types of smaller installations, not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
<b>1.0</b>	<b>EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)</b>													
1.1	Service cable										✓	No		
1.2	Service head										✓	No		
1.3	Earthing arrangement										✓	No		
1.4	Meter tails										✓	No		
1.5	Metering equipment										✓	No		
1.6	Isolator (where present)										✓	No		
<b>2.0</b>	<b>PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)</b>										N/A	No		
<b>3.0</b>	<b>EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)</b>													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓	No		
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										✓	No		
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										✓	No		
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										✓	No		
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓	No		
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓	No		
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓	No		
3.8	Accessibility and condition of other protective bonding connections (543.3.1;543.3.2)										✓	No		
<b>4.0</b>	<b>CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)</b>													
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)										✓	No		
4.2	Security of fixing (134.1.1)										✓	No		
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓	No		
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										✓	No		
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)										✓	No		
4.6	Presence of main linked switch (as required by 462.1.201)										✓	No		
4.7	Operation of main switch (functional check) (643.10)										✓	No		
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)										LIM	No		
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)										✓	No		
4.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)										✓	No		
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board (514.14)										✓	No		
4.12	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)										✓	No		
4.13	Presence of other required labelling (please specify) (Section 514)										✓	No		
4.14	Compatibility of protective devices, bases and other components; correct type and rating (No signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)										✓	No		
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)										✓	No		
4.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)										✓	No		
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)										✓	No		
4.18	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)										LIM	No		
4.19	RCD(s) provided for additional protection/requirements - includes RCBOs (411.3.3;415.1)										LIM	No		
4.20	Confirmation of indication that SPD is functional (651.4)										LIM	No		
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)										✓	No		
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A	No		
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A	No		
<b>5.0</b>	<b>FINAL CIRCUITS</b>													
5.1	Identification of conductors (514.3.1)										✓	No		
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)										✓	No		
5.3	Condition of insulation of live parts (416.1)										✓	No		

**CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED**

**GL00000566 - Master**

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
<b>5.0</b>	<b>FINAL CIRCUITS (Continued)</b>													
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓	No		
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										✓	No		
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓	No		
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓	No		
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)										✓	No		
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)										✓	No		
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓	No		
5.10	Concealed cables installed in prescribed zones (see Section D, Extent and limitations) (522.6.202)										✓	No		
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D, Extent and limitations) (522.6.204)										✓	No		
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:													
5.12.1	For all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)										✓	No		
5.12.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓	No		
5.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)										✓	No		
5.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)										✓	No		
5.12.5	Final circuits supplying luminaires within domestic (household) premises (411.3.4)										✓	No		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										✓	No		
5.14	Band II cables segregated/separated from Band I cables (528.1)										✓	No		
5.15	Cables segregated/separated from communications cabling (528.2)										✓	No		
5.16	Cables segregated/separated from non-electrical services (528.3)										✓	No		
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										✓	No		
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓	No		
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓	No		
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)										✓	No		
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))										✓	No		
5.19	Suitability of accessories for external influences (512.2)										✓	No		
5.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)										✓	No		
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)										✓	No		
<b>6.0</b>	<b>LOCATION(S) CONTAINING A BATH OR SHOWER</b>													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)										✓	No		
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										✓	No		
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)										✓	No		
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)										✓	No		
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)										✓	No		
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										✓	No		
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)										✓	No		
6.8	Suitability of current-using equipment for particular position within the location (701.55)										✓	No		
<b>7.0</b>	<b>OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)									Number of locations	0	No		

**Inspected By**

Name: **M A Jones**

Date: **03/08/2022**

Signature: 





Board Details		TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Location of Distribution Board	Main Hall Facing Cupboard	Supply to distribution board is from:	SubMains(DB 1, 2/L3)
Distribution board designation	DB 2	No of phases	1
		Nominal Voltage	230 V
		Overcurrent protective device for the distribution circuit	
		Type BS(EN)	60898 MCB C
		Rating	63 A
		Associated RCD (if any)	
		BS(EN)	N/A
		RCD No of Poles	N/A
		RCD Rating	N/A mA

Circuit Details															
Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times (s)	Overcurrent protective device					RCD		Maximum permitted Zs (Ω)
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>		BS(EN)	AFDD	Type	Rating (A)	Short circuit capacity (kA)	Operating current (ΔIn)		
1/L3	Door entry & bar area sockets	A	C	9	2.5	1	0.4	60898 MCB		B	32	10	30	1.37	
2/L3	Hall & stage area sockets	A	C	22	2.5	1	0.4	60898 MCB		B	32	10	30	1.37	
3/L3	High level wall sockets Hall	A	C	4	2.5	1	0.4	60898 MCB		B	20	10	30	2.19	
4/L3	Fire Alarm supply	A	C	1	2.5	1	0.4	60898 MCB		B	20	10	30	2.19	
5/L3	Kitchen lights	A	C	3	1.5	1	0.4	60898 MCB		B	10	10	30	4.37	
6/L3	Immersion Heater	A	C	1	2.5	1	0.4	60898 MCB		B	16	10	30	2.73	
7/L3	Hall wall spot lights	A	C	8	2.5	1	0.4	60898 MCB		B	6	10	30	7.28	
8/L3	Changing room area lights	A	C	7	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
9/L3	Stage/Bar/Alcove lights	A	C	17	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
10/L3	Store light	A	C	1	1	1	0.4	60898 MCB		B	6	10	30	7.28	
11/L3	Radial supply	A	C	1	6	2.5	0.4	60898 MCB		B	32	10	30	1.37	
12/L3	First floor sockets/ boiler supply	A	C	11	1	1	0.4	60898 MCB		B	32	10	30	1.37	
13/L3	Kitchen area sockets	A	C	10	2.5	1	0.4	60898 MCB		B	32	10	30	1.37	
14/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-	
15/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-	
16/L3	Main Hall Fluorscent lights	A	C	8	1.5	1	0.4	60898 MCB		B	10	10	30	4.37	
17/L3	Common area lights	A	C	2	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
18/L3	Stair/entrance/office lights	A	C	8	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
19/L3	Meeting room/store lights	A	C	5	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
20/L3	Unknown	A	C	1	1.5	1	0.4	60898 MCB		B	16	10	30	2.73	
21/L3	External building lighting	A	C	6	1.5	1	0.4	60898 MCB		B	6	10	30	7.28	
22/L3	Main hall emergency lights	A	C	4	1.5	1	0.4	60898 MCB		B	10	10	30	4.37	

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

TO BE COMPLETED IN EVERY CASE		TEST INSTRUMENTS (SERIAL NUMBERS) USED	
Correct supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate) <input type="checkbox"/> N/A	Earth fault loop impedance <input type="text" value="101368647 meggar"/> RCD <input type="text" value="101368647 meggar"/>	
Supplementary Conductors <input checked="" type="checkbox"/>		Insulation resistance <input type="text" value="101368647 meggar"/> Multi-function <input type="text" value="N/A"/>	
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION		Continuity <input type="text" value="101368647 meggar"/> Other <input type="text" value="N/A"/>	
Zs <input type="text" value="0.26"/> Ω	lpf <input type="text" value="1.623"/> kA		
Operating times of associated RCD (if any) At I Δ n <input type="text" value="N/A"/> ms			


Details of circuits and/or equipment vulnerable to damage

N/A

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance					Polarity (✓)	Maximum measured earth fault loop impedance Ω	RCD			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Test Voltage	Live/Live MΩ	Live/Neutral MΩ	Live/Earth MΩ	Earth/Neutral MΩ			Operating time at I Δ n (ms)	Test button operation	AFDD Test button operation	
	r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	(R <sub>2</sub> )											
1/L3	0.49	0.49	0.80	0.23	N/A	500	N/A	+999	+999	+999	✓	0.43	39.8	✓		NO
2/L3	0.66	0.67	1.06	0.50	N/A	500	N/A	+999	+999	+999	✓	0.69	39.8	✓		NO
3/L3	N/A	N/A	N/A	0.20	N/A	500	N/A	+999	+999	+999	✓	0.40	39.8	✓		NO
4/L3	N/A	N/A	N/A	0.14	N/A	500	N/A	+999	+999	+999	✓	0.34	39.8	✓		NO
5/L3	N/A	N/A	N/A	0.41	N/A	500	N/A	+999	+999	+999	✓	0.60	39.8	✓		NO
6/L3	N/A	N/A	N/A	0.30	N/A	500	N/A	+999	+999	+999	✓	0.48	39.8	✓		NO
7/L3	N/A	N/A	N/A	0.63	N/A	500	N/A	+999	+999	+999	✓	0.81	39.8	✓		NO
8/L3	N/A	N/A	N/A	0.80	N/A	500	N/A	+999	+999	+999	✓	0.99	39.8	✓		NO
9/L3	N/A	N/A	N/A	1.26	N/A	500	N/A	+999	+999	+999	✓	1.48	39.8	✓		NO
10/L3	N/A	N/A	N/A	0.18	N/A	500	N/A	+999	+999	+999	✓	0.36	39.8	✓		NO
11/L3	N/A	N/A	N/A	0.44	N/A	500	N/A	+999	+999	+999	✓	0.44	8.81	✓		NO
12/L3	0.55	0.55	0.89	0.52	N/A	500	N/A	+999	+999	+999	✓	0.72	8.81	✓		NO
13/L3	0.31	0.30	0.51	0.20	N/A	500	N/A	+999	+999	+999	✓	0.40	8.81	✓		NO
14/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16/L3	N/A	N/A	N/A	0.60	N/A	500	N/A	+999	+999	+999	✓	0.80	8.81	✓		NO
17/L3	N/A	N/A	N/A	0.36	N/A	500	N/A	+999	+999	+999	✓	0.55	8.81	✓		NO
18/L3	N/A	N/A	N/A	0.82	N/A	500	N/A	+999	+999	+999	✓	1.10	8.81	✓		NO
19/L3	N/A	N/A	N/A	0.42	N/A	500	N/A	+999	+999	+999	✓	0.62	8.81	✓		NO
20/L3	N/A	N/A	N/A	0.02	N/A	500	N/A	+999	+999	+999	✓	0.33	8.81	✓		NO
21/L3	N/A	N/A	N/A	1.00	N/A	500	N/A	+999	+999	+999	✓	1.22	8.81	✓		NO
22/L3	N/A	N/A	N/A	0.40	N/A	500	N/A	+999	+999	+999	✓	0.68	8.81	✓		NO

Tested By

Signature		Position	Test Engineer
Name	M A Jones	Date of testing	02/08/2022











Agreed limitations including the reasons, Continued. from page 1

hall

DB 4, 1/L3, Socket Cluster 1 - Remarks

Mainswitch operation defunct