

Call No 84022

Site Address
 HAWKESBURY UPTON
 PARISH HALL
 HAWKESBURY UPTON
 GL9 1BH

Date 26/10/17

Engineer A Nicolson

FIREMARK

Firemark Limited, BFF Business Park, Bath Road
 Bridgwater, Somerset TA6 4NZ
 Tel: 01278 727460 Fax: 01278 727461
 maintenance@firemark-ltd.co.uk
 www.firemark-ltd.co.uk



CERTIFICATE OF INSPECTION

WORK CARRIED OUT

EQUIPMENT	SIZE	SERVICED	NON CONFORMING	EQUIPMENT	SIZE	SERVICED	NON CONFORMING
WATER	6 ltr	2		CO2	2 kg	2	
	9 ltr				5 kg		
WATER ADDITIVE	3 ltr			FOAM	2 ltr		
	6 ltr	1			3 ltr		
POWDER	1 kg				6 ltr	4	
	2 kg	1		9 ltr			
	4 kg			WET CHEMICAL	3 ltr		
	6 kg				6 ltr		
	9 kg			FIRE BLANKET	-	2	1

GENERAL COMMENTS:

FIRE BLANKET @ ROOF OF STAGE MISSING
 WATER CAN ID SIGN MISSING @ RECEPTION
 FOAM ID SIGN MISSING IN KITCHEN
 UNABLE TO CONTACT LORRAINE BUTLER QUOTE NO FEEL

Recommendation Left: Yes No Number:

Apart from non-conforming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS5306 Part 3.

Customer Email _____

Customer Sign _____

Print PP Hutton

Engineer Sign _____

Print Nicolson