

Property:

HAWKES Hawkesbury
Upton Parish Hall
High Street,
Hawkesbury Upton,
Glos, , GL9 1BH

Task:

T-19432

Issued:

1st December 2022

Technician(s):

Karl Maslen

Issued by:

Pauline McKenzie

Scope of Works

Fire Extinguishers & Blankets: Annual (0)

0	Critical Defects	A defect that renders a system inoperative.
0	Non-critical Defects	A system impairment not likely to critically affect the operation of the system.
0	Non-conformances	Missing information or incorrect feature that does not affect the system operation.
0	Recommendations	A modification suggested to improve the system performance.
0	Informational Notes	Detailed advice or general comment.

Servicing Summary

Service	Asset	Quantity
Fire Extinguishers & Blankets: Annual	Fire Blanket	1
Fire Extinguishers & Blankets: Annual	Fire Extinguishers - Portable	10

Maintenance

Fire Extinguishers & Blankets: Annual

BS 5306-3 2017

Asset	Status
001 - 1.2 M x 1.2 M Fire Blanket Hall Kitchen	PASS
034 - Water 6.0 L Portable Fire Extinguisher Changing Rooms Fire Exit	PASS
033 - CO2 2.0 KG Portable Fire Extinguisher Inside Boiler Room near Changing Rooms	PASS

032 - Water 6.0 L Portable Fire Extinguisher	Upstairs Meeting Room	PASS
031 - Water 6.0 L Portable Fire Extinguisher	Upstairs Landing	PASS
030 - CO2 2.0 KG Portable Fire Extinguisher	Stage Fire Exit	PASS
029 - AFFF 6.0 L Portable Fire Extinguisher	Main Hall near Stage	PASS
028 - CO2 2.0 KG Portable Fire Extinguisher	Hall Kitchen	PASS
027 - CO2 2.0 KG Portable Fire Extinguisher	Parish Hall Main Entrance	PASS
026 - Water 6.0 L Portable Fire Extinguisher	Parish Hall Main Entrance	PASS
025 - AFFF 6.0 L Portable Fire Extinguisher	Parish Hall Main Entrance	PASS

Technician Notes

Upstairs Office may need Co2 for electrical cover but as the door was locked I couldn't see if there was one already in situated.

Signatures

Performed by Karl Maslen

