

PAT Report Passes For all Sites and Locations

Company Name: Hawkesbury Village Hall



Address: High Street
Hawkesbury Upton
GL9 1AU

Company Name: Glenroy Ltd

Address: 20 Siston Park
Kingswood
Bristol
South Glos
BS15 4PE

Telephone: 07971075561

Fax

Email: glenroyelectrical01@hotmail.co.uk

Signature:

Order Number:

File Name: Hawkesbury Upton Hall 2025.PAT

Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id Overall Status	Appliance Description	Test Date	Visual Polarity			(Ohms)	Insulation	Load	Leakage	
			Earth	Continuity	(MOhms)	(kVA)				(mA)
12A	LEAD	15/01/25	P	P	P	0.09	P >99.99	S	S	PASS
11A	LEAD	15/01/25	P	P	P	0.09	P >99.99	S	S	PASS
13A	16A TO 13A CONVERTER	15/01/25	P	P	P	0.04	P >99.99	S	S	PASS
24A	16A EXTENSION LEAD	15/01/25	P	P	P	0.04	P >99.99	S	S	PASS
14A	16A TO 13A CONVERTER	15/01/25	P	P	P	0.04	P >99.99	S	S	PASS
7A	PROJECTOR	15/01/25	P	S	S		P >99.99	S	S	PASS
6A	IEC LEAD	15/01/25	P	P	P	0.05	P >99.99	S	S	PASS
25A	16A EXTENSION LEAD	15/01/25	P	P	P	0.04	P >99.99	S	S	PASS
10A	LEAD	15/01/25	P	P	P	0.06	P >99.99	S	S	PASS
8A	EXTENSION LEAD	15/01/25	P	P	P	0.07	P >99.99	S	S	PASS
15A	FRIDGE	15/01/25	P	S	S		P >99.99	S	S	PASS
18A	LEAD	15/01/15	P	P	P	0.07	P >99.99	S	S	PASS
17A	PAPER SHREDER	15/01/15	P	S	S		P >99.99	S	S	PASS
19A	SPD LEAD	15/01/15	P	P	P	0.07	P >99.99	S	S	PASS
21A	PROJECTOR	15/01/15	P	S	S		P >99.99	S	S	PASS
20A	SINGING MACHINE	15/01/15	P	S	S		P >99.99	S	S	PASS
23A	LEAD	15/01/25	P	P	P	0.03	P >99.99	S	S	PASS
16A	BOTTLE CHILLER	15/01/25	P	S	S		P >99.99	S	S	PASS
23A	LEAD	15/01/25	P	P	P	0.19	P >99.99	S	S	PASS
16A	SPD LEAD	15/01/15	P	P	P	0.04	P >99.99	S	S	PASS
22A	OYPLA	15/01/25	P	S	P	0.09	P >99.99	P 0.33	P <0.10	PASS
3A	ELECTRIC HOB	15/01/25	P	S	P	0.08	P 26.34	P 0.62	P 0.12	PASS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id Overall Status	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (MOhms)		Load (mA)		Overall Status
					(Ohms)	Insulation	(kVA)	Leakage	
2A	KETTLE	15/01/25	P	S	P 0.09	P 56.23	P 0.25	P <0.10	PASS
28A	LIGHT	15/01/25	P	S	P 0.04	P >99.99	P <0.05	P <0.10	PASS
4A	LEAD	15/01/25	P	P	P 0.03	P >99.99	S	S	PASS
30A	LIGHT	15/01/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
31A	LIGHT	15/01/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
29A	LIGHT	15/01/25	P	S	P 0.10	P >99.99	P <0.05	P 0.10	PASS
1A	MICROWAVE	15/01/25	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
5A	IEC LEAD	15/01/25	P	P	P 0.03	P >99.99	S	S	PASS
26A	16A EXTENSION LEAD	15/01/25	P	P	P 0.04	P >99.99	S	S	PASS
27A	16A EXTENSION LEAD	15/01/25	P	P	P 0.04	P >99.99	S	S	PASS
01	CYGNET BOILER	15/01/25	P	S	P 0.09	P >99.99	P 1.37	P <0.10	PASS
2	KETTLE	15/01/25	P	S	S	P >99.99	S	S	PASS
03	KETTLE	15/01/25	P	S	P 0.08	P >99.99	P 1.82	P <0.10	PASS
04	WATER BOILER	15/01/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
05	MICROWAVE	15/01/25	P	S	P 0.08	P 9.80	P 0.32	P 0.30	PASS
06	BUFFALO	15/01/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
06	MICROWAVE	15/01/25	P	S	P 0.03	P >99.99	P <0.05	P <0.10	PASS
7	FLOOR WASHER	15/01/25	P	S	S	P >99.99	S	S	PASS
8	VACUME HETTY	15/01/25	P	S	S	P >99.99	S	S	PASS
09	BLENDER	15/01/25	P	S	S	P >99.99	S	S	PASS
10	DISH WASHER	15/01/25	P	S	P 0.09	P >99.99	P <0.05	P 0.65	PASS
11	LINCAT BOILER	15/01/25	P	S	P 0.08	P >99.99	P 1.46	P <0.10	PASS
12	FRIDGE	15/01/25	P	S	P 0.04	P >99.99	P <0.05	P <0.10	PASS
15	CHILLER	15/01/25	P	S	S	P >99.99	S	S	PASS
17	IET LEAD	15/01/25	P	P	P 0.05	P >99.99	S	S	PASS
18	INDUCTION HOB	15/01/25	P	S	P 0.04	P 29.49	P 1.71	P 0.11	PASS
19	INDUCTION HOB	15/01/25	P	S	P 0.09	P 61.15	P 0.61	P <0.10	PASS
20	LEAD	15/01/25	P	P	P 0.04	P >99.99	S	S	PASS
21	LEAD	15/01/25	P	P	P 0.04	P >99.99	S	S	PASS
24	CYGNET BOILER	15/01/25	P	S	P 0.08	P >99.99	P 1.43	P <0.10	PASS
25	GYGNET BOILER	15/01/25	P	S	P 0.08	P >99.99	P 1.40	P <0.10	PASS
26	SLOW COOKER	15/01/25	P	S	P 0.03	P 99.98	P <0.05	P <0.10	PASS
29	BOTTLE CHILLER	15/01/25	P	S	S	P >99.99	S	S	PASS
35	PRINTER	15/01/15	P	S	S	P >99.99	S	S	PASS
36	HIKVISION	15/01/15	P	P	P 0.04	P >99.99	S	S	PASS
38	MONITOR	15/01/15	P	P	P 0.04	P >99.99	S	S	PASS
45	PEDASTOL FAN	15/01/25	P	S	S	P >99.99	S	S	PASS
46	BURCO	15/01/25	P	S	P 0.08	P >99.99	P 1.15	P <0.10	PASS
47	WATER BOILER	15/01/25	P	S	P 0.07	P 12.20	P 1.22	P <0.10	PASS
49	SLOW COOKER	15/01/25	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
50	SLOW COOKER	15/01/25	P	S	P 0.08	P >99.99	P 0.05	P <0.10	PASS
56	PHONE	15/01/15	P	S	S	P >99.99	S	S	PASS

Total Appliances > **64**

Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	(Ohms)	(MOhms)	Load	(mA)
Overall Status				Earth Continuity	Insulation	(kVA)	Leakage	
				Total Appliances For Report:			64	